

DOUGLAS A. DUCEY
Governor



CAROL DITMORE
Director

**STATE OF ARIZONA
DEPARTMENT OF HOUSING**

1110 WEST WASHINGTON, SUITE 280
PHOENIX, ARIZONA 85007

PHONE: 602-771-1000 FAX: 602-771-1002
WWW.AZHOUSING.GOV

Installation Plan Submittal Memorandum
Effective July 1, 2018

June 18, 2018

RE: Available Fault Current and Calculations

Installation plan submittals will require the available fault current and calculations be included with the one-line electrical drawing. The one-line electrical drawing is to identify the utility connection from the site provided electrical power source to the proposed structure.

The following is to be noted as part of the one-line electrical drawing:

- AIC* rating of the factory built building provided load center(s)
- AIC* rating of the site provided electrical power source
- Calculations to identify maximum fault current based on system size and location

*AIC - Ampere Interrupting Capacity

Reference the 2008 NEC Article 110.9 & 110.10

Thank you.
Patricia E. Stecher
Plans Reviewer, Manufactured Housing Division
Arizona Department of Housing